



SANITARY CERTIFICATE



Ref. L. Dis. No. 3604/A4/2025

District Health Office, Nagercoil
Dt:

THE TAMILNADU EDUCATIONAL RULES CHAPTER-III (Rule 24 & Appendix-3)

I hereby declare that I have caused to be inspected the
.....MAYA KRISHNA SWAMY VIDYALAYA.....(CBSE).....
ANANTHANAGAR, ATHENCODE, S.T. MANKADU P.O., KILLIYOOR Taluk,
Kanyakumari District building and premises on 09/04/2025 and certify
that the accommodation provided for each of the several classes is sufficient for the
maximum number of pupils taught is maintained in substantial repair, that it is neat
and clean, that the latrine arrangements are adequate and satisfactory, that the supply
of drinking water is wholesome and that in all other necessary respects the sanitation
is satisfactory.

This certificate valid from Date of issue to one year

Certificate is issued with the following conditions :

1. Establishing hand wash facilities at the entrance.
2. All the employees should wear face mask.
3. Maintaining social distancing in all places.
4. Practicing cough etiquette properly.
5. Floors and frequently touched surfaces should be disinfected as per the infection prevention control guidelines.
6. Environment and campus should be kept clean and neat and should be free from Dengue Aedes Larva.
7. Provide safe and protected drinking water.
8. First Aid box should be maintained with drugs properly.
9. Tobacco prohibition board should be displayed as per COTPA 2003.

Countersigned on the basis of the BHS inspection finding.

Principal
Maya Krishna Swamy Vidyalaya
Ananda Nager, Athencode
S.T. Mankad P.O., K.K. Dist. - 629 172

Health Officer
Nagercoil



09/04/2025
BLOCK HEALTH SUPERVISOR
GOVT. PRIMARY HEALTH CENTRE
ARUDESAM, S.T. MANKAD P.O.
K.K. DIST.

MANAGER
Maya Krishna Swamy Vidyalaya
Ananda Nager, Athencode
S.T. Mankad P.O., K.K. Dist. - 629 172

**TEST REPORT**

ULR No: TC1005125000003567F

LRI No: AEL25050547A

Report Date: 20.05.2025

Page 1 of 2

CUSTOMER DETAILS

Customer Name & Address
M/s. Maya Krishna Swamy Vidyalaya
Anantha Nagar, Athencode,
S.T. Mankad P.O., Kanyakumari.

Customer Reference
Test Request dated: 15.05.2025

**SAMPLE DETAILS**

Product Category	Water	Sample Code	EN25050349
Sample Name	Ground Water	Sample Received on	15.05.2025
Sample Description by Customer	Bore Well Water	Sample Conditions at Receipt	Fit for Analysis
Sample Quantity & Packing	1 Ltr X 2 No's	Test Commenced on	15.05.2025
Sampled by	Not drawn by laboratory	Test Completed on	20.05.2025
Testing performed at	Permanent Facility	Information Provided by Customer	--

TEST RESULTS - CHEMICAL DISCIPLINE

Sl. No.	PARAMETERS	TEST METHOD	UNIT	RESULT	Requirements as per IS 10500:2012	
					Acceptable Limit	Permissible limit in the absence of Alternate Source
1	pH value@25°C	IS 3025 (Part-11):2022	--	6.64	6.5 to 8.5	No Relaxation
2	Electrical Conductivity@25°C	IS 3025 (Part-14):2013	µS/cm	433	--	--
3	Colour	IS 3025 (Part-4):2021	Hazen	3	Max 5	Max 15
4	Odour	IS 3025 (Part-5):2018	--	Agreeable	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part-10):2023	NTU	< 1.0	Max 1	Max 5
6	Total Dissolved Solids@180°C	IS 3025 (Part-16):2023	mg/L	240	Max 500	Max 2000
7	Total Hardness as CaCO ₃	IS 3025 (Part-21):2009	mg/L	73	Max 200	Max 600
8	Calcium as Ca	IS 3025 (Part-40):1991	mg/L	23	Max 75	Max 200
9	Magnesium as Mg	IS 3025 (Part-46):1994	mg/L	4.0	Max 30	Max 100
10	Chloride as Cl	IS 3025 (Part-32):1988	mg/L	98	Max 250	Max 1000
11	Total Alkalinity as CaCO ₃	IS 3025 (Part-23):2023	mg/L	63	Max 200	Max 600
12	Phenolphthalein Alkalinity	IS 3025 (Part-23):2023	mg/L	NIL	--	--
13	Carbonate Hardness as CaCO ₃	IS 3025 (Part-21):2009	mg/L	63	--	--
14	Non-Carbonate Hardness as CaCO ₃	IS 3025 (Part-21):2009	mg/L	10	--	--
15	Iron as Fe	IS 3025 (Part-53) (1,10 Phenanthroline Method):2003	mg/L	< 0.05	Max 1.0	No Relaxation
16	Sulphate as SO ₄	IS 3025 (Part-24) Sec 1:2022	mg/L	7.2	Max 200	Max 400
17	Nitrate as NO ₃	IS 3025 (Part-34):1988	mg/L	< 2.0	Max 45	No Relaxation
18	Silica as SiO ₂	IS 3025 (Part-35):1988	mg/L	6.2	--	--

Asha A

TM - Biological

Authorized Signatory

Maya Krishna Swamy Vidyalaya
Ananda Nager, Athencode
S.T. Mankad P.O., K.K. Dist. - 629 172

Principal

MANAGER

Maya Krishna Swamy Vidyalaya
Ananda Nager, Athencode
S.T. Mankad P.O., K.K. Dist. - 629 172

Mugilan K

TM Chemical

Authorized Signatory

The results are related to the sample tested and this report shall not be reproduced except in full without the written approval of the laboratory.

AEL/QAD/FRM/100/01-00

www.asianenvirolabs.com

E-mail : info@asianenvirolabs.com

Tel.: 91-44-2266 0411, 2266 0511